Outdoor unit	RXM60N2V1B9						
Indoor unit	FTXM60N2V1B						
Function			Heating season				
Cooling	Yes			Average (mandatory)	Yes		
Heating	Yes			Warmer (if designated)	Yes		
				Colder (if designated) No			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Design Load	Symbol	Value	Om	Seasonal efficiency	Symbol	Ivalue	John
Cooling	Pdesignc	6.00	kW	Cooling	SEER	6.90	-
heating / Average	Pdesignh	4.80	kW	heating / Average	SCOP / A	4.30	-
heating / Warmer	Pdesignh	2.58	kW	heating / Warmer heating / Colder	SCOP / W SCOP / C	5.51	ŀ
heating / Colder	Pdesignh		kW	realing / Colder	SCOP/C		
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor				Declared energy efficiency ratio*, at indoor temper	ature 27(19)	°C and outdoor t	emperature Tj
temperature Tj	D.L.	0.00	1.14/	T. 0500	FEDU	0.00	
Tj = 35°C Tj = 30°C	Pdc Pdc	6.00 4.42	kW kW	Tj = 35 °C Tj = 30 °C	EERd EERd	3.39 4.82	-
Tj = 25°C	Pdc	2.84	kW	$T_i = 25^{\circ}C$	EERd	7.99	ŀ
Tj = 20°C	Pdc	1.83	kW	Tj = 20°C	EERd	13.49	-
Declared capacity* for heating / Average season , at indoor temperature 20 °C				Declared coefficient of performance* / Average sea	eon at indo	or tomporaturo 2	0 °C and outdoor
and outdoor temperature Tj				temperature Tj			
Tj = -7°C	Pdh	4.25	kW	Tj = -7°C	COPd	2.68	-
Tj = 2°C	Pdh	2.58	kW	$Tj = 2^{\circ}C$	COPd	4.31	-
Tj = 7°C	Pdh Bdb	1.66	kW	$T_j = 7^{\circ}C$ $T_i = 12^{\circ}C$	COPd COPd	5.64	-
$Tj = 12 \degree C$ Tj = bivalent temperature	Pdh Pdh	1.95 4.25	kW kW	Tj = 12°C Tj = bivalent temperature	COPd COPd	6.82 2.68	-
Tj = operating limit	Pdh	4.25 3.12	kW	Tj = operating limit	COPd	2.08 2.05	
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Ti = 2°C	Pdh	2.58	kW	Ti = 2°C	COPd	4.31	-
Tj = 7°C	Pdh	1.66	kW	$T_j = 7 ° C$	COPd	5.64	-
Tj = 12°C	Pdh	1.95	kW	Tj = 12°C	COPd	6.82	-
Tj = bivalent temperature	Pdh	2.58	kW	Tj = bivalent temperature	COPd	4.31	-
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd	2.05	-
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor			
outdoor temperature Tj				temperature Tj	1	-	
Tj = -7°C	Pdh		kW	$Tj = -7^{\circ}C$	COPd		-
Tj = 2°C Ti = 7°C	Pdh Pdh		kW kW	Tj = 2°C Tj = 7°C	COPd COPd		-
Tj = 12°C	Pdh		kW	Ti = 12°C	COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-
Tj = -15°C	Pdh		kW	Tj = -15°C	COPd		
Bivalent temperature				Operating limit temperature			
heating / Average	Tbiv		°C	heating / Average	Tol	-20	°C
heating / Warmer	Tbiv	2	°C	heating / Warmer	Tol		°C
heating / Colder	Tbiv		°C	heating / Colder	Tol		°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc		kW	for cooling	EERcyc		-
for heating	Pcych	0.05	kW	for heating	COPcyc	0.05	-
Degradation co-efficient cooling**	Cdc	0.25	1	Degradation co-efficient cooling**	Cdh	0.25	-
				Annual electricity consumption			
off mode	Poff	0.001	kW	Cooling	<sup>Q</sup> CE	304	kWh/a
		0.001	1.3.47			1 500	
standby mode	<sup>P</sup> sb	0.001	kW	heating / Average	QНЕ	1,562	kWh/a
thermostat-off mode		0.012	kW	heating / Warmer		656	kWh/a
	PTO	0.012			ΩΗΕ	550	a a a a a a a a a a a a a a a a a a a
crankcase heater mode	POK	0.0	kW	heating / Colder			kWh/a
	PCK				QHE		
Capacity control		٦		Other items			
Capacity control	N	1		Sound power level (indoor/outdoor)		60 / 63	db(A)
					└WA		
staged	N			Global warming potential	GWP	675	kgCO <b>2</b> eq.
							-
variable	Ν			Rated air flow (indoor/outdoor)	-	17.1 / 46.6	m <sup>3</sup> /min
		_	_				
Contact datails for obtaining many	DAIKIN EUROPE Zandvoordestraat						
Contact details for obtaining more information	B-8400 Oostende						
	Belgium						
L							
for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.							

\* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit. \*\* if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.