

Outdoor unit	RXP71M2V1B
Indoor unit	FTXP71M2V1B

<b>Function</b>		<b>Heating season</b>	
Cooling	Yes	Average (mandatory)	Yes
Heating	Yes	Warmer (if designated)	Yes
		Colder (if designated)	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
<b>Design Load</b>				<b>Seasonal efficiency</b>			
Cooling	Pdesignc	7.1	kW	Cooling	SEER	6.20	-
heating / Average	Pdesignh	6.20	kW	heating / Average	SCOP / A	4.01	-
heating / Warmer	Pdesignh	3.34	kW	heating / Warmer	SCOP / W	5.57	-
heating / Colder	Pdesignh		kW	heating / Colder	SCOP / C		-

Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio*, at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35 °C	Pdc	7.10	kW	Tj = 35 °C	EERd	2.64	-
Tj = 30 °C	Pdc	5.23	kW	Tj = 30 °C	EERd	4.15	-
Tj = 25 °C	Pdc	3.36	kW	Tj = 25 °C	EERd	8.50	-
Tj = 20 °C	Pdc	2.60	kW	Tj = 20 °C	EERd	10.4	-

Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	5.48	kW	Tj = -7 °C	COPd	2.26	-
Tj = 2 °C	Pdh	3.34	kW	Tj = 2 °C	COPd	4.01	-
Tj = 7 °C	Pdh	2.15	kW	Tj = 7 °C	COPd	5.50	-
Tj = 12 °C	Pdh	2.07	kW	Tj = 12 °C	COPd	7.00	-
Tj = bivalent temperature	Pdh	5.48	kW	Tj = bivalent temperature	COPd	2.26	-
Tj = operating limit	Pdh	4.24	kW	Tj = operating limit	COPd	1.96	-

Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	3.34	kW	Tj = 2 °C	COPd	4.01	-
Tj = 7 °C	Pdh	2.15	kW	Tj = 7 °C	COPd	5.50	-
Tj = 12 °C	Pdh	2.07	kW	Tj = 12 °C	COPd	7.00	-
Tj = bivalent temperature	Pdh	3.34	kW	Tj = bivalent temperature	COPd	4.01	-
Tj = operating limit	Pdh	4.24	kW	Tj = operating limit	COPd	1.96	-

Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh		kW	Tj = -7 °C	COPd		-
Tj = 2 °C	Pdh		kW	Tj = 2 °C	COPd		-
Tj = 7 °C	Pdh		kW	Tj = 7 °C	COPd		-
Tj = 12 °C	Pdh		kW	Tj = 12 °C	COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-
Tj = -15 °C	Pdh		kW	Tj = -15 °C	COPd		-

Bivalent temperature				Operating limit temperature			
heating / Average	Tbiv		°C	heating / Average	Tol	-15	°C
heating / Warmer	Tbiv	2	°C	heating / Warmer	Tol	-15	°C
heating / Colder	Tbiv		°C	heating / Colder	Tol		°C

Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc		kW	for cooling	EERcyc		-
for heating	Pcych		kW	for heating	COPcyc		-
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-

Electric power input in power models other than 'active mode'				Annual electricity consumption			
off mode	Poff	0.001	kW	Cooling	QCE	401	kWh/a
standby mode	Psb	0.001	kW	heating / Average	QHE	2,166	kWh/a
thermostat-off mode	Pto	0.015	kW	heating / Warmer	QHE	839	kWh/a
crankcase heater mode	PCK	0.0	kW	heating / Colder	QHE		kWh/a

Capacity control				Other items			
fixed	N			Sound power level (indoor/outdoor)	LWA	62 / 66	db(A)
staged	N			Global warming potential	GWP	675	kgCO <sub>2</sub> eq.
variable	N			Rated air flow (indoor/outdoor)		16.8 / 45.5	m <sup>3</sup> /min

<b>Contact details for obtaining more information</b>	<b>DAIKIN EUROPE N.V.</b> Zandvoordestraat 300 B-8400 Oostende Belgium
---	---

\* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.  
 \*\* if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.