SolaX Power Network Technology (Zhejiang) CO.,Ltd.

Address Room 206, Western Area, A Building, Zhejiang University Science and Technology Park, No. 525,

Xixi Rd, Hangzhou, Zhejiang, China, 310007

Tel +86-571-56260008 Fax +86-571-56075753 Web www.solaxpower.com Email info@solaxpower.com



1.1. CALPANASPONEDOS DE CONTRACTOR

DECLARATION OF CONFORMITY

According to Directive (EU) 2016/631

The European Commission Regulation(EU) 2016/631 is establishing a network code on requirement for grid connection of generators(RfG in short).

The RfG will be effective as of April 27th 2019. For now many EU member states are still working on definition of the national details, most will be based on the European Standards EN50549-1/-2 or VDE-AR-N 4105:2018.

We: SOLAX POWER NETWORK TECHNOLOGY (ZHEJIANG) CO.,LTD. Manufacture Address: No.288, Shizhu Rd, Tonglu County, Zhejiang Province 311500 P.R.CHINA

hereby declares that below Grid-tied PV Inverter models comply with followed directive: VDE-AR-N 4105:2018.

Inverter Models:

Series X3-Hybrid-5.0-N-C; X3-Hybrid-5.0-D-C

X3-Hybrid-5.0-N-E; X3-Hybrid-5.0-D-E X3-Hybrid-6.0-N-C; X3-Hybrid-6.0-D-C X3-Hybrid-6.0-N-E; X3-Hybrid-6.0-D-E X3-Hybrid-8.0-N-C; X3-Hybrid-8.0-D-C X3-Hybrid-8.0-N-E; X3-Hybrid-8.0-D-E X3-Hybrid-10.0-N-C; X3-Hybrid-10.0-D-C X3-Hybrid-10.0-N-E; X3-Hybrid-10.0-D-E

X3-Fit-8.0E; X3-Fit-8.0C X3-Fit-10.0E; X3-Fit-10.0C

Firmware requirements: DSP 4.33 and above ARM 4.27 and above

And now we are working intensively on implementing the new standards EN50549-1, and it will be certified by third party certification authority in the near future.

GNO HNAME:

NAME & SURNAME:

POSITION: R&D Director SIGNATURE: Guo Huawei