

Model name

AM09BP UA3 (Outdoor unit) / AM09BP NSJ (Indoor unit)

Function (indicate if present)			If the function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.		
cooling	Y		Average (mandatory)	Y	
heating	Y		Warmer (if designated)	N	
			Colder (if designated)	N	

Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	2,5	kW	cooling	SEER	6,5	-
heating / Average	Pdesignh	2,4	kW	heating / Average	SCOP/A	4,0	-
heating / Warmer	Pdesignh	x,x	kW	heating / Warmer	SCOP/W	x,x	-
heating / Colder	Pdesignh	x,x	kW	heating / Colder	SCOP/C	x,x	-

Declared capacity* for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				Declared Energy efficiency ratio* for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
Tj=35°C	Pdc	2,50	kW	Tj=35°C	EERd	3,73	-
Tj=30°C	Pdc	1,85	kW	Tj=30°C	EERd	5,84	-
Tj=25°C	Pdc	1,19	kW	Tj=25°C	EERd	8,15	-
Tj=20°C	Pdc	1,29	kW	Tj=20°C	EERd	12,65	-

Declared capacity* for heating / Average climate, at indoor temperature 20°C and outdoor temperature Td				Declared Coefficient of performance* for heating / Average climate, at indoor temperature 20°C and outdoor temperature Td			
Tj=-7°C	Pdh	2,13	kW	Tj=-7°C	COPd	2,92	-
Tj=2°C	Pdh	1,30	kW	Tj=2°C	COPd	4,05	-
Tj=7°C	Pdh	0,84	kW	Tj=7°C	COPd	4,45	-
Tj=12°C	Pdh	1,11	kW	Tj=12°C	COPd	6,38	-
Tj=bivalent temperature	Pdh	2,22	kW	Tj=bivalent temperature	COPd	3,05	-
Tj=operating limit	Pdh	2,40	kW	Tj=operating limit	COPd	2,80	-

Declared capacity* for heating / Warmer climate, at indoor temperature 20°C and outdoor temperature Tj				Declared Coefficient of performance* / Warmer climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	Pdh	x,x	kW	Tj=2°C	COPd	x,x	-
Tj=7°C	Pdh	x,x	kW	Tj=7°C	COPd	x,x	-
Tj=12°C	Pdh	x,x	kW	Tj=12°C	COPd	x,x	-
Tj=bivalent temperature	Pdh	x,x	kW	Tj=bivalent temperature	COPd	x,x	-
Tj=operating limit	Pdh	x,x	kW	Tj=operating limit	COPd	x,x	-

Declared capacity* for heating / Colder climate, at indoor temperature 20°C and outdoor temperature Tj				Declared Coefficient of performance* / Colder climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	x,x	kW	Tj=-7°C	COPd	x,x	-
Tj=2°C	Pdh	x,x	kW	Tj=2°C	COPd	x,x	-
Tj=7°C	Pdh	x,x	kW	Tj=7°C	COPd	x,x	-
Tj=12°C	Pdh	x,x	kW	Tj=12°C	COPd	x,x	-
Tj=bivalent temperature	Pdh	x,x	kW	Tj=bivalent temperature	COPd	x,x	-
Tj=operating limit	Pdh	x,x	kW	Tj=operating limit	COPd	x,x	-

Bivalent temperature				Operating limit temperature			
heating / Average	Tbiv	-8	°C	heating / Average	Tol	-10	°C
heating / Warmer	Tbiv	x	°C	heating / Warmer	Tol	x	°C
heating / Colder	Tbiv	x	°C	heating / Colder	Tol	x	°C

Cycling interval capacity				Cycling interval efficiency			
for cooling	Pccyc	x,x	kW	for cooling	EERcyc	x,x	-
for heating	Pchyc	x,x	kW	for heating	COPcyc	x,x	-

Degradation co-efficient				Degradation co-efficient			
cooling**	Cdc	0,25	-	heating**	Cdh	0,25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	P _{OFF}	0,006	kW	cooling	Q _{CE}	134	kWh/a
standby mode	P _{SB}	0,006	kW	heating / Average	Q _{HE}	840	kWh/a
thermostat-off mode	P _{TO}	0,013	kW	heating / Warmer	Q _{HE}	xx	kWh/a
crankcase heater mode	P _{CK}	0	kW	heating / Colder	Q _{HE}	xx	kWh/a

Capacity control (indicate one of three options)				Other items			
fixed	N			Sound power level (indoor/outdoor)	L _{WA}	59 / 65	dB(A)
staged	N			Global warming potential	GWP	2087.5	kgCO ₂ eq.
variable	Y			Rated air flow (indoor/outdoor)	-	690 / 1620	m ³ /h

Contact details for obtaining more information	Christianna PAPAZHARIOU		
	Internal communicator - Energy & environment regulations expert		
	LG Electronics		
	Paris Nord II – 117 avenue des Nations		
	BP 59372 Villepinte – 95942 Roissy CDG Cedex		
	chris.papazahariou@lge.com		
	Tel. +33 1 49 89 57 41, +33 6 83 077 455		

*= For staged capacity units, two values divided by a slash ("/") will be declared in each box in the section "Declared capacity of the unit" and "declared EER/COP" of the unit.

**= If default Cd=0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.

