

| | | | | | | |
|--|---|------------------------|--------------|--|--|--|
| Außengerät | RXC35DV1B | | | | | |
| Innengerät | FTXC35DV1B | | | | | |
| Function | | | | | | |
| Kühlen | Ja | Average (mandatory) | Ja | | | |
| Heizen | Ja | Warmer (if designated) | Ja | | | |
| | | Colder (if designated) | Nein | | | |
| Element | Symbol | Wert | Gerät | | | |
| Design Load | | | | | | |
| Kühlen | Pdesignc | 3.44 | kW | | | |
| heating / Average | Pdesignh | 2.24 | kW | | | |
| heating / Warmer | Pdesignh | 2.06 | kW | | | |
| heating / Colder | Pdesignh | 1.31 | kW | | | |
| Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj | | | | | | |
| Tj = 35 °C | Pdc | 3.44 | kW | | | |
| Tj = 30 °C | Pdc | 2.41 | kW | | | |
| Tj = 25 °C | Pdc | 1.57 | kW | | | |
| Tj = 20 °C | Pdc | 1.31 | kW | | | |
| Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj | | | | | | |
| Tj = -7 °C | Pdh | 1.98 | kW | | | |
| Tj = 2 °C | Pdh | 1.26 | kW | | | |
| Tj = 7 °C | Pdh | 0.990 | kW | | | |
| Tj = 12 °C | Pdh | 1.11 | kW | | | |
| Tj = Bivalent temperature | Pdh | 1.98 | kW | | | |
| Tj = operating limit | Pdh | 1.36 | kW | | | |
| Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj | | | | | | |
| Tj = 2 °C | Pdh | 2.06 | kW | | | |
| Tj = 7 °C | Pdh | 1.39 | kW | | | |
| Tj = 12 °C | Pdh | 1.11 | kW | | | |
| Tj = Bivalent temperature | Pdh | 2.06 | kW | | | |
| Tj = operating limit | Pdh | - | | | | |
| Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj | | | | | | |
| Tj = -7 °C | Pdh | - | kW | | | |
| Tj = 2 °C | Pdh | - | kW | | | |
| Tj = 7 °C | Pdh | - | kW | | | |
| Tj = 12 °C | Pdh | - | kW | | | |
| Tj = Bivalent temperature | Pdh | - | kW | | | |
| Tj = operating limit | Pdh | - | kW | | | |
| Tj = -15 °C | Pdh | - | kW | | | |
| Bivalent temperature | | | | | | |
| heating / Average | Tbiv | -7 | °C | | | |
| heating / Warmer | Tbiv | 2 | °C | | | |
| heating / Colder | Tbiv | 0 | °C | | | |
| Cycling interval capacity | | | | | | |
| for cooling | Pcyc | - | kW | | | |
| for heating | Pcyh | - | kW | | | |
| Degradation co-efficient cooling** | Cdc | 0.25 | - | | | |
| Electric power input in power models other than 'active mode' | | | | | | |
| Off mode | Poff | 0.002 | kW | | | |
| Standby mode | Psbt | 0.002 | kW | | | |
| Thermostat-off mode | PTO | 0 | kW | | | |
| Crankcase heater mode | PCK | 0 | kW | | | |
| Capacity control | | | | | | |
| Fest | N | | | | | |
| Gestaffelt | N | | | | | |
| Variable | N | | | | | |
| Contact details for obtaining more information | Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium | | | | | |
| * for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit. | | | | | | |
| ** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required. | | | | | | |